



ÁSHAMAR 35

ÁSHAMAR 33

ÁSHAMAR 31

**HÚS 35**

OPN. NR.	HEMAMESTA NR.	MESTA LENGD	VARMA-ÞÉRF	TENG.	OPNLOKI (DANFOSS)
11	1	2x55	2x70	1000	CD AB RAVL 10/6 kv=0.2
21	2	100	55	706	CD
31	3	100	55	706	AB
41	4	130	55	905	AB
51	5	50	55	215	AB FJVR
61	6	120	55	353	AD RAVL 10/6 kv=0.2
71	7	330	90	2023	AD kv=0.4
81	8	120	55	671	CD FJVR
101	10	330	55	2459	AB RAVL 10/6 kv=0.4
111	11	280	55	1510	CD

**HÚS 33**

OPN. NR.	HEMAMESTA NR.	MESTA LENGD	VARMA-ÞÉRF	TENG.	OPNLOKI (DANFOSS)
11	1	130	55	1066	CD RAVL 10/6 kv=0.2
21	2	100	55	812	AB
31	3	2x55	2x70	849	AB CD
41	4	60	55	200	CD
51	5	100	55	281	AD
61	6	330	90	1728	CD RAVL 10/6 kv=0.4
71	7	100	55	375	CD RAVL 10/6 kv=0.2
81	8	300	55	2460	CD RAVL 10/6 kv=0.4
91	9	100	55	845	AB RAVL 10/6 kv=0.2

**HÚS 31**

OPN. NR.	HEMAMESTA NR.	MESTA LENGD	VARMA-ÞÉRF	TENG.	OPNLOKI (DANFOSS)
11	1	130	55	1066	AB RAVL 10/6 kv=0.2
21	2	100	55	812	CD
31	3	55	70	849	CD
32	3	55	70	849	AB
41	4	60	55	200	AB
51	5	100	55	281	AD
61	6	330	90	1728	AB RAVL 10/6 kv=0.4
71	7	100	55	375	AB RAVL 10/6 kv=0.2
81	8	300	55	2460	AB RAVL 10/6 kv=0.4
91	9	100	55	845	CD RAVL 10/6 kv=0.6