



INNTAKSRÖR SKULU VERA 70 cm. UNDIR ENDANLEGU YFIRBORÐI  
 INNTAKSRÖR RAFVETU  $\varnothing$  50 mm + 3 x  $\varnothing$  20 mm FYRIR LÖBARLÝSNGU  
 INNTAKSRÖR FYRIR SIMA / INTERNET  $\varnothing$  50 mm +  $\varnothing$  32 mm  
 INNTAKSRÖR LEGGST AD LÖBARHÖRÐUM  
 HEMTAUG RAFVETU 400V / 240 V, 3 x 50 A

INNTAKSRÖR SKULU VERA 70 cm. UNDIR ENDANLEGU YFIRBORÐI  
 INNTAKSRÖR RAFVETU  $\varnothing$  50 mm + 3 x  $\varnothing$  20 mm FYRIR LÖBARLÝSNGU  
 INNTAKSRÖR FYRIR SIMA / INTERNET  $\varnothing$  50 mm +  $\varnothing$  32 mm  
 INNTAKSRÖR LEGGST AD LÖBARHÖRÐUM  
 HEMTAUG RAFVETU 400V / 240 V, 3 x 50 A

<p>Ervergi 32 Selfossi, sími 482 3480 &amp; 897 8718        ÚTPRENTAD: 10.11.2020 09:51:22        SLÖB: F:\001\Verk\Áshamar 95 - 103\Teikningar        SÍBAST VISTAD: 9.10.2020 22:16:14        Samþykkt        Afritun aðalhönnuðar</p>	Þór Stefánsson Raðionfræðingur Kennitala: 211281-3749 nellingrafteikn@gmail.com	VERKHEITI: Raðhús Áshamar 95 - 103 Vestmannaeyjum VERKHLUTI: Lágspennulagnir, smáspennulagnir og lampaplan Áshamar 101	BLAD 7 af 8
	Br: Dags. DAGSETNING 7 október 2020	Hannad TÖLVUNAFN Rafteign 2010-2357.dwg Mkv: 150 VERKNUMER: 2357-2020-054	