



| B | Gildleiki roftauga | mm ² | AL | Cu | AL | Cu | Cu | Cu | Cu |
|---|--------------------|-----------------|----------|-------|-------------|-------------|-------------------------|-------------------------|------|
| | | | 3x150+50 | 25 | 3x70+25 | 5x16 | 5x10 | 5x1,5 | 5x15 |
| | Afl | kW | | | 76 | 30 | 15 | 0,55 | |
| | Straumur | A | | | (145) | (57) | (30) | (1,8) | |
| | Kapalúmer | | 301W1 | 301W3 | 301W5/1W430 | 301W7/1W434 | 301W11 | 301W12/1W447 | |
| | Raðtengjanúmer | | | | | | 301X11 L1,L2,L3,N,PE | 301X12 L1,L2,L3,N,PE | |

| A | Texti |
|---|---|
| | ATH. UMHVERFISHITASTIG Í SAL GETUR FARID Í 50 °C |
| | STOFN/HEIMTAUG |
| | SPENNUNJÖFNUNARTAUG |
| | STYRTAFLA (CONTROL CUBICLE) 1EC01.01 |
| | KVORN (SHREDDER CONTROL CABINET) 1EC05.03 |
| | KRANI (CRANE-UNIT) |
| | STJÓRNING FÜR SILÓBAND (SILO CONVEYOR CONTROL CABINET) 1EC05.04 |
| | MOTORLÖSI VIÐ VARMASK |
| | Ohudala |

Leittréðingir sem sendar voru frá Ráðvís Hönnun
 frá Bajarveitum Vestmannaeyja (Fríðriki)

RÁÐVÍS HÖNNUN
 Grensásvegur 7, 105 Reykjavík
 Sími 91-35553, Fax 91-687391

Verk: VESTMANNAEYJABÆR-SORPBRENNSLUSTÖÐ
 RAFLAGNIR
 ADALTAFLA 7A1

Teikn. nr.: 1.301
 M.kv.: ~
 Dags.: 1992.06.30

Verk nr.: VB920631
 Breyting: *Leidrið skemmt
útfærsla rafurketa*
 Blað 1 af