


GRUNNMYND MILLILOFT BÍLGEYMSLU



$\Delta t = 40^\circ C.$

ATH ! OFNASTÆRDIR SKULU ATHUGAST Á STAÐNUM ÁÐUR EN OFNAPÖNTUN ER GERÐ.
 ALLIR OFNAR OG ALLT LAGNÆFNI SKAL Hafa VOTTUN AF ÞAR TLÆRUM AÐILA.

OFN. NR.	GERÐ	LENGD. CM.	HÆÐ. CM.	AFKÖST KCAL/H.	TENGING. FRAM. BAK.	VALDIR OFNAR. GERÐ. AFK.
01		100	60	650	C D	
02		110	60	1370	A B	
03		80	60	650	C D	
04		110	60	1200	A B	
05		105	30	1300	A B	Einungis í húsnr. 3
05A		250	30	1460	C D	Einungis í húsnr. 5
05B		300	60	1800	C D	
06		310	30	2500	A B	
07		110	60	930	A B	
08		110	60	930	C D	
09		70	60	400	C D	
10		50	60	400	C D	
11		300	70	2400	C D	

Óháskrá á v0 húsnr. 3 óhástengingar speglast í húsi nr 5.

STÓRAGERÐI 1A OG 1B VESTMANNÆYJUM.
 GRUNNMYND HITALÖGN.

16. jan. 2002. MKV. 1 : 50.

Jóhannes Pétursson 010448-3959 S - 567-5107

Sigurður Sigurðsson 021146-2349 S - 566-6613