



OFNASKRA

Nr	Herbergi	Varmapörf	Hámarks-		Valdir ofnar $\Delta t = 40$			Tenging	Oflokar			
			Wöll	Hæð	Lengd	Ríkost	Þykki		Hæð	Lengd	Dem. um DANFOSS loka	Gerð
1	Anddyri	700	75	60				CD	FJVR		3.5	
2	Snyrting	250	75	60				CB	"		3.0	
3.1	Stofa	2300	30	230				CD	RAVL	0.5		
3.2	"	2300	30	230				AD	FJVR		3.5	
4.1	Eldhúsi	1500	75	130				AD*	stillit			Radlengd. 7/10ritam
4.2	"	1500	75	130				AD*	RAVL	0.5		
5	Þvottur	1500	75	140				AD	FJVR		3.0	
6	Herbergi	900	75	140				CB	RAVL	0.2		
7	Bad	800	75	140				CB	FJVR		2.0	
8	Hjón	1740	75	140				CB	RAVL	0.5		
9	Herbergi	1100	75	140				CB	"	0.5		
10	"	850	75	140				CB	"	0.2		
11	Samt	15.440										
11	Bilgeymsla											
	Innihiti 20%	5.400	75	250				AD	FJVR		3.5	
	Bilgeymsla											
	Innihiti 10%	3.800	75	250				AD	FJVR		3.5	
12	Kjall. bilgeymsl	1.300	75	200				AD	FJVR		3.0	

\* Radlengdir önnur 7/einum RAVL 0.5

VERK  
STORRGERÐIYO VESTMANNHEYJUM  
Rúmmynd valns og hitalögn

BR DAUS BREYTING TEIKN NR 32 8208  
PÁLL ZÓPHONIASSON HANNAB RG TEIKNAB  
BYGGINGATEKNIKERFRINGUR